

# 2013 California Building Code

## Title 24, Part 2, Chapter 12, Interior Environment

### SECTION 1252 [CA] BARBER COLLEGES AND SHOPS

**1252.1 Barber college floors.** Floors of barber colleges shall be covered with hardwood, linoleum, asphalt tile or some other washable and nonporous material other than paint.

**1252.2 Barber shop floors.** Floors of barber shops shall be covered with hardwood, linoleum, asphalt tile, carpeting or some other washable material other than paint.

**1252.3 Barber shop washbasin(s) and lavatory(ies).** A barber shop owner shall provide washbasin(s) or lavatory(ies) within the working area of the barber shop.

**1252.4 Minimum barber shop size.** A barber shop shall be a minimum of 8 feet (2438 mm) wide, 8 feet (2438 mm) long, with an 8-foot (2438 mm) ceiling.

**1252.5 Barber college premises.** In a college of barbering, the room for practical work and demonstrations shall be at least 14 feet (4267 mm) wide for one row of barber chairs and shall be at least 20 feet (6096 mm) wide for two rows of chairs.

### SECTION 1253 [CA] SCHOOLS OF COSMETOLOGY, COSMETOLOGICAL ESTABLISHMENTS AND SATELLITE CLASSROOMS

#### 1253.1 Floor space.

**1253.1.1 Schools of cosmetology.** The minimum floor space in any school of cosmetology premises shall be 3,000 square feet (279 m<sup>2</sup>), not less than 2,000 square feet (185.8 m<sup>2</sup>) of which shall be provided for the working, practice and classroom areas.

**Exception:** When the average daily attendance for either day or night school in a school of cosmetology exceeds 50 students for a period of three months, an additional 30 square feet (2.8 m<sup>2</sup>) of floor space shall be required for each additional student after the first 50, which shall be provided for the working, practice and classroom areas.

**1253.1.2 Schools of electrology.** The minimum floor space in any school of electrology premises shall be 1,000 square feet (93 m<sup>2</sup>), not less than 600 square feet (55.7 m<sup>2</sup>) of which shall be provided for the working, practice and classroom areas.

**Exception:** When the average daily attendance for either day or night school of electrology exceeds 15 students, an additional 30 square feet (2.8 m<sup>2</sup>) of floor space shall be required for each additional student after the first 15, which shall be provided for working, practice and classroom areas.

**1253.1.3 Satellite classrooms.** The minimum floor space in any satellite classroom of a school of cosmetology or electrology shall be 1,000 square feet (93 m<sup>2</sup>).

**Exception:** For each additional student after the first 50, an additional 20 square feet (1.9 m<sup>2</sup>) of floor space shall be required.

**1253.2 Floor finish.** The floors in the toilet area of each school and establishment shall be of nonabsorbent material.

**1253.3 Ceiling height.** The minimum ceiling height of the practice and classroom areas of school premises shall be at least 9 feet (2743 mm) in height.